

Important Information About Your Drinking Water

Monitoring Requirements *Not Met* for City of Lyndon

Dear Water Customer:

We are required to monitor your drinking water for specific contaminants on a regular basis. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards.

During the 4th quarter of 2020 we did not monitor for the disinfection by-products of Haloacetic Acids (HAA) and Total Trihalomethanes (TTHM) as required by Kansas Administrative Regulations. Even though this was not an emergency, as our customers you have a right to know what happened and what we did to correct the situation.

What should I Do?

Nothing. You do not need to use an alternative (e.g., bottled) water supply. *However, if you have specific health concerns, consult your doctor.*

What Does This Mean?

This is not an immediate risk. If it had been, you would have been notified immediately. *However, some people who drink water containing trihalomethanes and/or haloacetic acids in excess of the MCL over many years may experience problems with their liver, kidneys, or central nervous systems, and may have increased risk of getting cancer.*

What Happened? What is being done?

The required 4th quarter test for TTHM and HAA was taken in October instead of November as required by the City of Lyndon monitoring plan. The monitoring plan was reviewed with the appropriate staff and corrections were made to testing procedures.

We anticipate resolving the problem within the 1st quarter of 2021.

For More Information-

Please contact SCOTT CULLEY at 785-828-3146. Or by Mail: 730 Topeka Ave., P.O. Box 287, Lyndon, KS 66451-0287

Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools, and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.

This notice is being sent to you by the **CITY OF LYNDON** - Federal ID# KS2013901

Distributed on June 2, 2021